

## Technical Rules exemptions granted by Western Power

### Register of exemptions for Technical Rules Clause 3.6.10.1(a)

Applicable clause	Exemption details
Technical Rules 2016; Clause 3.6.10.1(a)	<p><b>Protection</b></p> <p><i>Provision for protection functions for LV connected, &lt;1 MVA Inverter Embedded Generation as specified in clause 3.6.10 to be installed <b>away from the connection point at an equivalent point, where the equivalent point in the installation must meet all of the following requirements:</b></i></p> <ul style="list-style-type: none"><li><i>(i) The equivalent point is at a distribution board within the installation that connects the User's site load.</i></li><li><i>(ii) The equivalent point is no more than one distribution board downstream from the site's main distribution board and connection point.</i></li><li><i>(iii) The overcurrent protection at the equivalent point grades with the SPD and main switch(es).</i></li><li><i>(iv) The voltage rise to the equivalent point is less than 1%. The voltage rise calculation uses the rated output of the generation without any offset from load from the equivalent point to the connection point.</i></li></ul> <p>An exemption application for each qualifying connection point is still required.</p>



## Exemptions currently in force (as at 30 June 2019)

Exemption granted to:	Date granted	Date expiring
Regional Power Corporation (Horizon Power)	3/05/2019	Ongoing
South Pacific Laundry (Perth) Pty Ltd	6/05/2019	Ongoing
Bunnings Group Limited	6/05/2019	Ongoing
Intergrain Pty Ltd	22/05/2019	Ongoing
Rosewood Care Group (Inc)	24/05/2019	Ongoing
EPM Pty Ltd	28/05/2019	Ongoing
ALDI Stores (A Limited Partnership)	24/06/2019	Ongoing
ALDI Stores (A Limited Partnership)	24/06/2019	Ongoing